


1	2		3	4		5		6		7		8
POS	POSTBET.	ANT.	BESKRIVNING	ELEKTRISKA DATA	FABRIKAT	TYPNUMMER	BESTÄLLNINGSNUMMER	E-NUMMER	BLADREF	INDEX	ANMÄRKNING	
1	-AJ1	1	ISNIVÅVAKT E37-M1201	E37 230V	RANCO	E37-M1201	E37-M1201		/3.4C	AJ079		
2	-AJ2	1	TEMP. REGULATOR DIXELL	XR30CX PTC/NTC 230VAC	DIXELL	1704850	LGFDDBC500		/3.4A	AJ083		
3	-AJ3	1	TEMP. REGULATOR DIXELL	XR30CX PTC/NTC 230VAC	DIXELL	1704850	LGFDDBC500		/2.4B	AJ083		
4	-AS1	1	APPARATSKÅP PLÅTMECANO	ROSTFRI 370X320X170	PLÅTMECANO	1710460			/1.5B	AS041		
5	-BP1	1	PRESSOSTAT LCB-PA13 1.5-2.5P		AHSELL KYL	1203892			/4.3B	BP039		
6	-BP2	1	PRESSOSTAT HP ACB-2UC56W	VXL	TEMPCOLD	1203894	1203894		/4.3C	BP040		
7	-E1	1	VEVHUSVÄRMARE	PTC 35W	DANFOSS AB	1900100	PTC 35W		/2.6E	PA004		
8	-FB1	1	ÖVERSTRÖMSRELÄ	LR2K0314 5.5-8A	SCHNEIDER ELECT	1705865	LR2K0314	3236519	/1.3C	FB032		
9	-FC1	1	AUT. SÄKR. C60N 1P C10A	10A	SCHNEIDER ELEC	1705400	24310	2112216	/1.5B	FS001		
10	-H1	1	INDIKATORLAMP 230V RÖD	230V RÖD	ELFA	1701270	33-885-35		/2.6B	HL004		
11	-H2	1	INDIKATORLAMP 230V RÖD	230V RÖD	ELFA	1701270	33-885-35		/4.6C	HL004		
12	-H3	1	INDIKATORLAMP 230V RÖD	230V RÖD	ELFA	1701270	33-885-35		/4.6B	HL004		
13	-H4	1	INDIKATORLAMP 230V RÖD	230V RÖD	ELFA	1701270	33-885-35		/4.6E	HL004		
14	-K1	1	40.52 2VX 230VAC RELÄ	2VX 230VAC	ELGROSSIST	1708720	4006837	4006837	/4.6A	KA002		
15		1	95.75 SOCKEL T SERIE 40		ELGROSSIST	1708730	4006950	4006950	/4.6A	KA003		
16	-K2	1	40.52 2VX 230VAC RELÄ	2VX 230VAC	ELGROSSIST	1708720	4006837	4006837	/4.6D	KA002		
17		1	95.75 SOCKEL T SERIE 40		ELGROSSIST	1708730	4006950	4006950	/4.6D	KA003		
18	-K3	1	40.52 2VX 230VAC RELÄ	2VX 230VAC	ELGROSSIST	1708720	4006837	4006837	/4.6C	KA002		
19		1	95.75 SOCKEL T SERIE 40		ELGROSSIST	1708730	4006950	4006950	/4.6C	KA003		
20	-K4	1	40.52 2VX 230VAC RELÄ	2VX 230VAC	ELGROSSIST	1708720	4006837	4006837	/4.6E	KA002		
21		1	95.75 SOCKEL T SERIE 40		ELGROSSIST	1708730	4006950	4006950	/4.6E	KA003		
22	-K5	1	40.52 2VX 230VAC RELÄ	2VX 230VAC	ELGROSSIST	1708720	4006837	4006837	/4.6B	KA002		
23		1	95.75 SOCKEL T SERIE 40		ELGROSSIST	1708730	4006950	4006950	/4.6B	KA003		
24	-KM1	1	KONTAKTOR		SCHNEIDER	1705810	LC1K0901M7	3230634	/3.6D	KM001		
25	-KM2	1	KONTAKTOR		SCHNEIDER	1705810	LC1K0901M7	3230634	/2.6D	KM001		
26	-M1	1	KOMPRESSOR MTZ28JE4	7,5A	MANEUROP	1000490	MTZ28-4VI		/1.3D	MK030		
27	-M2	1	CIRK.PUMP CHI 2-50		GRUNDFOS AB	1001020	4H512105		/1.5D	MP006		
28	-R1	1	ISGIVARE L56-M3001	L56-M3001	RANCO				/3.2D	RT018		
29	-R2	1	TEMP. GIVARE DIXELL	NG6 1,5MT NTC PROBE	6X15 DIXELL	1701130	BN607001 51		/3.3C	RT003		
30	-R3	1	TEMP. GIVARE DIXELL	NG6 1,5MT NTC PROBE	6X15 DIXELL	1701130	BN607001 51		/2.3C	RT003		
31	-R4	1	MOTSTÅND 47K OHM NTC	47K OHM NTC	ELFA				/4.6C	R007		
						FRIGADON AB		MM SERVICE CENTER AB				
								MULTICOOLER - VK		FORTS.BL. 2 BL. 1		
						KONSTR. LAG		RITAD LAG		ANLÄGGNING: =A1		
						DATUM 181012		GODK.		RIT.NR. REV.		
								PLACERING: +AS1		33206-r01-007		
BET. ÄNDRINGEN AVSER		SIGN. DATUM										

1	2	3	4	5	6	7	8				
POS	POSTBET.	ANT.	BESKRIVNING	ELEKTRISKA DATA	FABRIKAT	TYPNUMMER	BESTÄLLNINGSGRUPP	E-NUMMER	BLADREF	INDEX	ANMÄRKNING
32	-S1	1	STRÖMBRYTARE 0-1,	A2/6ZM/F601	HEDTEC	1730850	A2/6ZM/F601		/2.3B	SQ067	
33	-S2	1	STRÖMBRYTARE 0-1,	A2/6ZM/F601	HEDTEC	1730850	A2/6ZM/F601		/3.3B	SQ067	
34	-S3	1	TRYCKKNAPP SVART SV RING	BRYTANDE NC	BEVING COMPOTEC	1700960	1.10001.151/0104		/4.3B	SS003	
35	-S4	1	TRYCKKNAPP LEGRAND	TR.KNP.STR.ST2P20A	LEGRAND	1702230	04463		/4.3A	SS001	
36	-T1	1	TRANSFORMATOR ELIWELL	220/24V 3VA	ELIWELL	1700540	TF111132		/2.6C	TS019	
37	-X1	22	KOPPLINGSPLINT WEIDMULLER	ZDU 2,5-2/3AN BEIGE	WEIDMULLER	1709700	1706010000	2919510	/1.5D	XT015	
38	-X2	1	JORDPLINT UTAN SOCKEL 1+8	PLINT UTAN SOCKEL	LEGRAND	1702270	04803		/1.2D	XP003	
39											
40											
41											
42											
43											
44											
45											
46											
47											
48											
49											
50											
51											
52											
53											
54											
55											
56											
57											
58											
59											
60											
61											
62											

BET. ÄNDRINGEN AVSER		SIGN. DATUM		FRIGADON AB			MM SERVICE CENTER AB MULTICOOLER - VK		FORTS.BL. 1 BL. 2	
KONSTR. LAG		RITAD LAG		ANLÄGGNING: =A1			RIT.NR		REV.	
DATUM 181012		GODK.		PLACERING: +AS1			33206-r01-008			



INKOMMANDE 400/3N/50
MAIN SUPPLY 400/3N/50

KOMPRESSOR
COMPRESSOR

ISVATTENPUMP
PUMP ICE WATER PUMP

(VEVHUSVÄRMARE)
(CRANK CASE HEATER)

LÅGTRYCKSPRESSOSTAT
LOW PRESSURE CONTROL

HÖGTRYCKSPRESSOSTAT
HIGH PRESSURE CONTROL

ISSENSOR
ICE PROBE

TEMPERATUR SENSOR
TEMPERATURE SENSOR
(BATH. TEMP.)

TEMPERATUR SENSOR
TEMPERATURE SENSOR
(PYTHON TEMP.)

TEMPERATURLARM
TEMPERATURE ALARM
24V AC 3VA

BET.	ÄNDRINGEN AVSER	SIGN.	DATUM

FRIGADON AB		MM SERVICE CENTER AB MULTICOOLER - VK	
KONSTR. LAG	RITAD LAG	ANLÄGGNING: =A1	FORTS.BL. BL. 1
DATUM 181012	GÖDK.	PLACERING: +AS1	RITN.NR. REV.
		33206-r01-006	